



PELLERGY

WOOD PELLET CENTRAL HEATING SYSTEMS

Certificate of Boiler Efficiency

The **Windhager BioWIN2 Pellet Boiler line** has been tested in accordance with alternative test method IDC dated January 03 2020 for compliance with EPA 40 CFR Part 60, March 16, 2015 by Research Institutes of Sweden AB, an EPA accredited independent laboratory

The following product is “qualified energy property” under Section 25D of the Internal Revenue Code.

Boiler Model	Calculated, EPA Annualized Efficiencies (HHV)	As-Tested, Steady State Efficiency (LHV)
Windhager BioWIN152	76.4%	93.8%
Windhager BioWIN262	81.0%	93.9%
Windhager BioWIN332	82.7%	94.8%

Under penalties of perjury, I declare that I have examined this certification statement, and to the best of my knowledge and belief, the facts are true, correct, and complete.

Andrew L Boutin,
Founder & General Manager